
THIS DRAWING IS INTENDED ONLY AS A GUIDE AND NOT AS A REPLACEMENT FOR PROFESSIONALLY ENGINEERED PROJECT DRAWINGS. THIS CONCEPT SYSTEM DRAWING DOES NOT IMPLY COMPLIANCE WITH LOCAL BUILDING CODES, ACTUAL INSTALLATION MAY VARY DEPENDING ON INSTALLATION LOCATION AND PRAMMETERS AND IT MUST BE DONE IN ACCORDANCE TO ALL LOCAL BUILDING CODES, VERIFY WITH LOCAL BUILDINGS OFFICIALS BEFORE COMMENCEMENT OF SYSTEM INSTALLATION. CHANGES OR MODIFICATIONS TO PIPING OR DESIGN IS NOT TO BE PERFORMED WITHOUT EXPRESSED WRITTEN PERMISSION BY NAVIEN, INC.



	TANKLESS QUANTITY: RECOMMENDED PIPE SIZE	1 UNIT: 3/4" 2 UNITS: 1"	3 UNITS: 1-1/4" 4-5 UNITS: 1-1/2" 6-8 UNITS: 2" 9-14 UN	IITS: 2-1/2" 15-16 UNITS: 3"		SYMBOL LEGEND		
ſ	Navien 20 GOODYEAR IRVINE, CA 92618 800-519-8794	NPE-S2 SERIES TANKLESS WATER HEATER			UNION	CHECK VALVE	FULL-PORT VALVE	PRESSURE RELIEF VALVE
		(1) NPE-S2 TANKLESS WATER HEATER INCLUDES MODELS 150, 180, 210 AND 240				1 4 1/2/2	POT WEIG	イ VALVE
	www.navieninc.com	DRAWN BY: S. STOEKE	NPE-S2-1	MAY 17, 2021				