THIS DRAWING IS INTENDED ONLY AS A GUIDE AND NOT AS A REPLACEMENT FOR PROFESSIONALLY ENGINEERED PROJECT DRAWINGS. THIS CONCEPT SYSTEM DRAWING DOES NOT IMPLY COMPLIANCE WITH LOCAL BUILDING CODES. ACTUAL INSTALLATION MAY VARY DEPENDING ON INSTALLATION LOCATION AND PARAMETERS AND IT MUST BE DONE IN ACCORDANCE TO ALL LOCAL BUILDING CODES. VERIFY WITH LOCAL BUILDING OFFICIALS BEFORE COMMENCEMENT OF SYSTEM INSTALLATION. CHANGES OR MODIFICATIONS TO PIPING OR DESIGN IS NOT TO BE PERFORMED WITHOUT EXPRESSED WRITTEN PERMISSION BY NAMEN, INC. SYSTEM SYSTEM RETURN **SUPPLY** SUPPLY(S) RETURN(S) **SENSOR SENSOR** 12" MAX φφφφφ CIRC ZONE PANEL BOILER #1 BOILER #2 (MASTER) THERMOSTATIC THERMOSTATIC MIXING VALVE MIXING VALVE (IF REQUIRED) (IF REQUIRED) INDIRECT WATER HEATER INDIRECT WATER **HEATER** NFB-H UNIT CAN INTERNALLY CONTROL UP TO 3 ZONE CIRCULATORS, WITHOUT A ZONE CONTROL PANEL (1) INSTALLED. ANY ADDITIONAL ZONES SHALL REQUIRE A CIRC ZONE PANEL. REFER TO NAVIEN I & O MANUAL FOR П ADDITIONAL INFORMATION. **-**W 1 1 1 1 CONDENSATE SYMBOL LEGEND FULL-PORT VALVE BACKFLOW PREVENTER EXPANSION TANK PRESSURI RELIEF VALVE ----- CONTROL WIRING THERMOSTAT NFB-H SERIES BOILER BALL DRAIN VALVE MNavien AIR ELIMINATION CONDENSATE TRAP (2) NFB-H BOILERS WITH (2) INDIRECT WATER HEATERS OUTDOOR TEMPERATURE SENSOR PRESSURE REDUCING VALVE Ŵ 函 AUTOMATIC AIR VENT COMMON SECONDARY INJECTION PIPING 20 GOODYEAR IRVINE, CA 92618 INCLUDES MODELS NFB-175H, 200H 800-519-8794 WYE STRAINER
W/ BLOWDOWN SEPTEMBER 27, 2021 S. STOEKE NFB-H-2-ZC-MULT-IDWH-2 www.navieninc.com