
THIS DRAWING IS INTENDED ONLY AS A GUIDE AND NOT AS A REPLACEMENT FOR PROFESSIONALLY ENGINEERED PROJECT DRAWINGS. THIS CONCEPT SYSTEM DRAWING DOES NOT IMPLY COMPLIANCE WITH LOCAL BUILDING CODES. ACTUAL INSTALLATION MAY YARY DEPENDING ON INSTALLATION LOCATION AND PARAMETERS AND IT MUST BE DONE IN ACCORDANCE TO ALL LOCAL BUILDING CODES. VERIFY WITH LOCAL BUILDING COPES. VERIFY WITH LOCAL BUILDING OFFICIALS BEFORE COMMENCEMENT OF SYSTEM INSTALLATION. CHANGES OR MODIFICATIONS TO PIPING OR DESIGN IS NOT TO BE PERFORMED WITHOUT EXPRESSED WRITTEN PREMISSION BY NAVIEN, INC. ● CONDENSATE HYDRONIC FEED WATER OPTIONAL DHW RECIRCULATION --A MODEL DOMESTIC COLD WATER ı DOMESTIC HOT . WATER GAS SYSTEM RETURN 6" MIN. 12" MAX OPTIONAL NAVI-CLEAN SHOWN





www.navieninc.com

				SYMBOL LEGEND		
	NFC-H SERIES COMBI-BOILER & NPE (A2/S2) SERIES TANKLESS			BACKFLOW PREVENTER	CHECK VALVE	i i i i i i i i i i i i i i
	(1) NFC-H COMBI-BOILER		PREVENIER	1 V VALVE	~~	
	WITH (7) NPE-A2 OR S2 TANKLESS WATER HEATERS			CONTROL WIRING	PRESSURE RELIEF VALVE	ϕ
INCLUDES MODELS NFC-250/175H, NFC-250/200H			,,,,,,	AIP	97	
N BY:	S. STOEKE	NFC-H-1-NPE-A2-S2-7-ZP	MAY 31, 2022	CASCADE CABLE	ELIMINATION	4

FULL-PORT VALVE

-CIRCULATOR

NAVICLEAN FILTER

EXPANSION TANK

= UNION

T) THERMOSTAT