THIS DRAWING IS INTENDED ONLY AS A GUIDE AND NOT AS A REPLACEMENT FOR PROFESSIONALLY ENGINEERED PROJECT DRAWINGS. THIS CONCEPT SYSTEM DRAWING DOES NOT IMPLY COMPILANCE WITH LOCAL BUILDING CODES. ACTUAL INSTALLATION MAY YARY DEPENDING ON INSTALLATION LOCATION AND PRANMETERS AND IT MUST BE DONE IN ACCORDANCE TO ALL LOCAL BUILDING CODES. VERIFY WITH LOCAL BUILDINGS OFFICIALS BEFORE COMMENCEMENT OF SYSTEM INSTALLATION. CHANGES OR MODIFICATIONS TO PIPING OR DESIGN IS NOT TO BE PERFORMED WITHOUT EXPRESSED WRITTEN PRIMISSION BY NAVIEN, INC. DOMESTIC HOT WATER TO FIXTURES AIRFLOW DOMESTIC COLD WATER CIRCULATOR REQUIREMENT: BRONZE OR STAINLESS STEEL SELECT & SET: 4 GPM MAX @ 19 FT HEAD TANKLESS QUANTITY: RECOMMENDED PIPE SIZE 2 UNITS: 1" 3 UNITS: 1-1/4" 4-5 UNITS: 1-1/2" 6-8 UNITS: 2" 9-14 UNITS: 2-1/2" 15-16 UNITS: 3" 1 UNIT: 3/4" SYMBOL LEGEND NPN-U SERIES TANKLESS WATER HEATER FULL-PORT VALVE UNION (1) NPN-U TANKLESS WATER HEATER COMBI WITH AIR HANDLER .... DHW CIRCULATOR
W/ PUMP WIRE
AND CHECK VALVE PRESSURI RELIEF VALVE SHOWN WITH NAVIEN PUMP WIRE ACCESSORY AND H2AIR KIT CIRCULATOR 20 GOODYEAR IRVINE, CA 92618 INCLUDES MODELS 150, 180 AND 199 800-519-8794 函 CONTROL WIRING THERMOSTAT S. STOEKE NPN-U-1-EC-H2AIR DECEMBER 7, 2020 www.navieninc.com