
THIS DRAWING IS INTENDED ONLY AS A GUIDE AND NOT AS A REPLACEMENT FOR PROFESSIONALLY ENGINEERED PROJECT DRAWINGS. THIS CONCEPT SYSTEM DRAWING DOES NOT IMPLY COMPLIANCE WITH LOCAL BUILDING CODES, ACTUAL INSTALLATION MAY VARY DEPENDING ON INSTALLATION LOCATION AND PARAMETERS AND IT MUST BE DONE IN ACCORDANCE TO ALL LOCAL BUILDING CODES, VERIFY WITH LOCAL BUILDINGS OFFICIALS BEFORE COMMENCEMENT OF SYSTEM INSTALLATION. CHANGES OR MODIFICATIONS TO PIPING OR DESIGN IS NOT TO BE PERFORMED WITHOUT EXPRESSED WRITTEN PRIMISSION BY AVIEN, INC.

- (A) TANKLESS CIRCULATOR (BRONZE OR SS) SELECTED CIRCULATOR SHALL BE 20 GPM MAXIMUM (5 TANKLESS, 4 PER TANKLESS) @ 23' TOTAL HEAD (10 PSI) + PIPE, VALVES, FITTINGS & TANK.
- (B) INSTALL CIRCUIT SETTERS TO MAINTAIN FLOW INTO UNITS @ 4 GPM MAXIMUM.



TANKLESS QUANTITY: RECOMMENDED PIPE SIZE 1 UNIT: 3/4" 2 UNITS: 1" 3 UNITS: 1-1/4" | 4-5 UNITS: 1-1/2" | 6-8 UNITS: 2" | 9-14 UNITS: 2-1/2" | 15-16 UNITS: 3" SYMBOL LEGEND NPE-S2 SERIES TANKLESS WATER HEATER FULL-PORT VALVE (T) AQUASTAT UNION (5) NPE-S2 TANKLESS WATER HEATERS PRESSURI RELIEF VALVE EXPANSION TANK WITH (1) STORAGE TANK TO MEET FLOW/TEMP RISE REQUIREMENT CIRCULATOR ---- CONTROL WIRING 20 GOODYEAR IRVINE, CA 92618 INCLUDES MODELS 150, 180, 210 AND 240 800-519-8794 BALANCING VALVE ····· CASCADE CABLE S. STOEKE NPE-S2-5-ST-1 MAY 12, 2022 www.navieninc.com